

**Specification for the rotary drum thickener/dewaterer
Siljan RotoMaster SF 17****Capacity in cubic meter per hour, municipal sludge;****DS 1-1.5 % ->6-8 % : 17-26 cbm/h or 170-255 kg DS/h****DS 0.5-1 %-> 4 %: 20-30 cbm/h or 170-255 kg DS/h**

As-built	Total length:	3225 mm
measures:	Width:	890 mm
	Height:	1170 mm
Weight, empty:		330 kg

Materials of construction: Stainless steel, AISI 304, or AISI 316L, except for the bearings (self lubricate Robalon), the filter cloth (polyester), the spray nozzles (brass) and the drive junction (aluminum).

Motor drive: 0.55 kW 3-phase asynchronous motor according to IEC standard

Electrical connections: 3x220/380 V voltage

Pipe connections

Sludge in/filtrate: DN 80 in/DN 110 out

**Control cabinet: Protection class IP 54, stainless steel
Necessary automatic protection included.**

Spraying water: Fresh water (process water as option)

Number of spray nozzles: 18 pcs.

Minimum pressure: 6 bar

**Water consumption: 1.8 cbm/h at continuous water spray,
normal spray interval, 20-30% → 0.37-0.55 cbm/h**

Process water consumption:3.0 cbm/h at continuous process water spray

Thickening/dewatering and polymer consumption:

The thickening/dewatering result and the polymer consumption depend on type of sludge, type of polymer selected, efficiency of polymer/water mixing, the efficiency of the mixing of polymer with sludge, the temperature, the time for and efficiency of flocculation before separation as well as selected thickening parameters of the drum thickener.

Type of sludge:	Thickened sludge: DS, %:	Polymerconsumption: kg/ton:
100 % biological excess sludge	5-8 %	1.5-2
Mixed sludge, 50 % bio, 50 % chem	6-9 %	2-3
Primary sludge	6-10 %	1-3
Digested sludge	10-12 %	2-4
External sludge	12-15 %	0-1

The control unit *Siljan PolySave* governs the polymer consumption to the lower part of those ranges.